

Trygg



miljø

- når sekundene teller!

HÅNDSLUKKER • FIRE EXTINGUISHER

6L SKUM (FOAM)

27A

183B



1. Dra ut sikrings splinten.
Pull out safety device.



2. Rett dysen mot bunnen av flammen.
Trykk ned utløserhåndtaket.

Direct nozzle at base of fire.
Depress handle.



KAN BRUKES MOT BRANN I ELEKTRISK ANLEGG MAKS 1000V
CAN BE USED ON LIVE ELECTRICAL EQUIPMENT MAX 1000V

TRYKKLADET SKUMSLUKKER

Eiers egenkontroll: Utføres iht. NS-3910: Hvert kvartal kontrolleres det at manometer-nålen står i det grønne feltet og at splinten er intakt og plumbert. Ved avvik, kontakt forhandler. I næring skal slukkeren ha faglig tilsyn årlig, i bolig hvert 5 år.

Destruksjon: Iht. NS-3910/Leveres miljøstasjon.

Slukkemiddel: 6 L. P Foam
Drivgass: N₂ - Nitrogen
Arbeidstrykk: 12 Bar ved +20°C
Temperaturområde: +5°C - +60°C

PRESSURIZED FOAM EXTINGUISHER

Control: According to NS-3910: Each quarter, check that the gauge is in the green field. In case of discrepancies, please contact dealer. In businesses the extinguisher should have professional service annually, in homes every five years.

Destruction: Acc. NS-3910/At recycling center.

Subsequent filling: 6 L. P Foam
Propellant: N₂ - Nitrogen
Working pressure: 12 Bar at +20°C
Temperature range: +5°C - +60°C

EN 3-7

CE 0409

DNV GL
(180-11)



S6 Eco PRO

Presto

DISTRIBUTØR: BSP AS

Postboks 596, 1411 Kolbotn Tel: 21555700 www.bsp.no

PRODUSENT: Presto Brandsäkerhet AB

Box 315 SE-641 23 Katrineholm, Sverige Tel +46 10 452 00 00 www.presto.se



UN 1044

104005-1510

M20006